



NELAC NJ11005  
EPA NJ01186  
PADEP 68-05417  
NYDOH NY12046  
BWON Approved



380 Scotch Road  
Ewing, NJ 08628  
609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

## CERTIFICATE OF ANALYSIS

NJ11005 / NY12046

Project Name: **Instructional Support Center**

Workorder: **N041774**

Jeremy Smith  
CNA Environmental  
27 Kent St  
Ballston Spa, NY 12020

Project Name and Number: **Instructional Support Center**

November 09, 2016

Dear Jeremy Smith,

This report relates only to the sample(s) as received by the laboratory. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your NJAL Environmental project coordinator or laboratory manager listed at the bottom of this report at (609)-737-3477

Note: This coverage is included as part of the Analytical Report and must be retained as a permanent record thereof.

  
Laboratory Manager





NELAC NJ11005  
EPA NJ01186  
PADEP 68-05417  
NYDOH NY12046  
BWON Approved



380 Scotch Road  
Ewing, NJ 08628  
609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

**Date Received:** 10/25/16 16:54

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041774-01	Lead	EPA 200.8	9.50	0.50	ug/L	15	International Support Ctr-01	10/4/16 06:59	10/28/16 23:51
N041774-02	Lead	EPA 200.8	8.73	0.50	ug/L	15	International Support Ctr-02	10/4/16 06:59	10/28/16 23:53
N041774-03	Lead	EPA 200.8	9.25	0.50	ug/L	15	International Support Ctr-03	10/4/16 06:59	10/28/16 23:55
N041774-04	Lead	EPA 200.8	4.94	0.50	ug/L	15	International Support Ctr-04	10/4/16 06:59	10/28/16 23:57
N041774-05	Lead	EPA 200.8	202	0.50	ug/L	15	International Support Ctr-05	10/4/16 06:59	10/29/16 00:08

*Stephen Witkowski*



NELAC NJ11005  
EPA NJ01186  
PADEP 68-05417  
NYDOH NY12046  
BWON Approved



380 Scotch Road  
Ewing, NJ 08628  
609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

### Notes and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

All work performed by New Jersey Analytical Laboratories LLC, is subject to our terms and conditions of services viewable at our office and our website: <http://www.njal.com/About-NJAL/Terms-and-Conditions.aspx>

*Stephen Witkowski*

Date of Sampling:	10-4-16
Samples Taken By:	PS.
Samples Taken By:	

BLDG NO./I Instructional Support Center 1070 Rt 9 Castleton, NY 12033
BLDG ADDRESS:
CONTACT NAME & NUMBERS:

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

[illegible]

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO<sub>3</sub>@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
	ML/SEL	11:00	10/17/16

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: CNA Environmental	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	