

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
CGE-01-SF-P-01	9/25/2020 04:54	10/9/2020 14:59	70148298001	Lead	<1.0	15	ug/L
CGE-01-DW-P-02	9/25/2020 04:56	10/9/2020 15:00	70148298002	Lead	<1.0	15	ug/L
CGE-01-BF-P-03	9/25/2020 04:56	10/9/2020 15:01	70148298003	Lead	<1.0	15	ug/L
CGE-01-SF-P-04	9/25/2020 04:57	10/9/2020 15:02	70148298004	Lead	1.9	15	ug/L
CGE-01-SF-P-15	9/25/2020 05:00	10/9/2020 15:03	70148298005	Lead	10.5	15	ug/L
CGE-01-SF-P-06	9/25/2020 05:01	10/9/2020 15:06	70148298006	Lead	<1.0	15	ug/L
CGE-01-SF-P-08	9/25/2020 05:03	10/9/2020 15:07	70148298007	Lead	1.7	15	ug/L
CGE-01-WF-P-09	9/25/2020 05:03	10/9/2020 15:08	70148298008	Lead	<1.0	15	ug/L
CGE-01-SF-P-10	9/25/2020 05:05	10/9/2020 15:08	70148298009	Lead	<1.0	15	ug/L
CGE-01-SF-P-11	9/25/2020 05:05	10/9/2020 15:09	70148298010	Lead	<1.0	15	ug/L
CGE-01-WF-P-12	9/25/2020 05:06	10/9/2020 15:10	70148298011	Lead	<1.0	15	ug/L
CGE-01-BF-P-13	9/25/2020 05:06	10/9/2020 15:11	70148298012	Lead	<1.0	15	ug/L
CGE-01-IM-P-14	9/25/2020 05:11	10/9/2020 15:18	70148298013	Lead	5.3	15	ug/L
CGE-01-KF-P-15	9/25/2020 05:11	10/9/2020 15:20	70148298014	Lead	5.2	15	ug/L
CGE-01-KS-P-16	9/25/2020 05:11	10/9/2020 15:21	70148298015	Lead	3.2	15	ug/L
CGE-01-SF-P-20	9/25/2020 05:25	10/9/2020 15:22	70148298016	Lead	1.0	15	ug/L
CGE-01-KS-P-21	9/25/2020 05:29	10/9/2020 15:23	70148298017	Lead	1.9	15	ug/L
CGE-01-KS-P-22	9/25/2020 05:29	10/9/2020 15:24	70148298018	Lead	<1.0	15	ug/L
CGE-01-SF-P-26	9/25/2020 05:32	10/9/2020 15:25	70148298019	Lead	<1.0	15	ug/L
CGE-01-SF-P-27	9/25/2020 05:40	10/9/2020 15:28	70148298020	Lead	1.2	15	ug/L
CGE-01-SF-P-28	9/25/2020 05:37	10/9/2020 15:29	70148298021	Lead	<1.0	15	ug/L
CGE-01-SF-P-30	9/25/2020 05:45	10/9/2020 15:30	70148298022	Lead	11.0	15	ug/L
CGE-01-WF-P-32	9/25/2020 05:42	10/9/2020 15:31	70148298023	Lead	1.0	15	ug/L
CGE-01-SF-P-33	9/25/2020 05:49	10/9/2020 15:32	70148298024	Lead	6.8	15	ug/L
CGE-01-WF-P-35	9/25/2020 05:50	10/9/2020 15:32	70148298025	Lead	<1.0	15	ug/L
CGE-01-SF-P-36	9/25/2020 05:51	10/9/2020 15:33	70148298026	Lead	<1.0	15	ug/L
CGE-01-SF-P-37	9/25/2020 05:52	10/9/2020 15:34	70148298027	Lead	<1.0	15	ug/L
CGE-01-1M-P-38	9/25/2020 05:25	10/9/2020 15:35	70148298028	Lead	<1.0	15	ug/L
CGE-01-1M-P-39	9/25/2020 05:26	10/9/2020 15:36	70148298029	Lead	<1.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

October 12, 2020

Paul Swieton
Rensselaer-Columbia-Greene Counties and
BOCES
10 Empire State Blvd.
Fl 2
Castleton On Hudson, NY 12033

RE: Project: LEADS 9/25
Pace Project No.: 70148298

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on October 06, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Ormond Beach

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Rebeka K. Smith for
Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: LEADS 9/25
Pace Project No.: 70148298

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174
Alaska DEC- CS/UST/LUST
Alabama Certification #: 41320
Arizona Certification# AZ0819
Colorado Certification: FL NELAC Reciprocity
Connecticut Certification #: PH-0216
Delaware Certification: FL NELAC Reciprocity
Florida Certification #: E83079
Georgia Certification #: 955
Guam Certification: FL NELAC Reciprocity
Hawaii Certification: FL NELAC Reciprocity
Illinois Certification #: 200068
Indiana Certification: FL NELAC Reciprocity
Kansas Certification #: E-10383
Kentucky Certification #: 90050
Louisiana Certification #: FL NELAC Reciprocity
Louisiana Environmental Certificate #: 05007
Maryland Certification: #346
Michigan Certification #: 9911
Mississippi Certification: FL NELAC Reciprocity
Missouri Certification #: 236

Montana Certification #: Cert 0074
Nebraska Certification: NE-OS-28-14
New Hampshire Certification #: 2958
New Jersey Certification #: FL022
New York Certification #: 11608
North Carolina Environmental Certificate #: 667
North Carolina Certification #: 12710
North Dakota Certification #: R-216
Ohio DEP 87780
Oklahoma Certification #: D9947
Pennsylvania Certification #: 68-00547
Puerto Rico Certification #: FL01264
South Carolina Certification: #96042001
Tennessee Certification #: TN02974
Texas Certification: FL NELAC Reciprocity
US Virgin Islands Certification: FL NELAC Reciprocity
Virginia Environmental Certification #: 460165
West Virginia Certification #: 9962C
Wisconsin Certification #: 399079670
Wyoming (EPA Region 8): FL NELAC Reciprocity

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: LEADS 9/25
Pace Project No.: 70148298

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
70148298001	CGE-01-SF-P-01	EPA 200.8	AMS	1	PASI-O
70148298002	CGE-01-DW-P-02	EPA 200.8	AMS	1	PASI-O
70148298003	CGE-01-BF-P-03	EPA 200.8	AMS	1	PASI-O
70148298004	CGE-01-SF-P-04	EPA 200.8	AMS	1	PASI-O
70148298005	CGE-01-SF-P-15	EPA 200.8	AMS	1	PASI-O
70148298006	CGE-01-SF-P-06	EPA 200.8	AMS	1	PASI-O
70148298007	CGE-01-SF-P-08	EPA 200.8	AMS	1	PASI-O
70148298008	CGE-01-WF-P-09	EPA 200.8	AMS	1	PASI-O
70148298009	CGE-01-SF-P-10	EPA 200.8	AMS	1	PASI-O
70148298010	CGE-01-SF-P-11	EPA 200.8	AMS	1	PASI-O
70148298011	CGE-01-WF-P-12	EPA 200.8	AMS	1	PASI-O
70148298012	CGE-01-BF-P-13	EPA 200.8	AMS	1	PASI-O
70148298013	CGE-01-IM-P-14	EPA 200.8	AMS	1	PASI-O
70148298014	CGE-01-KF-P-15	EPA 200.8	AMS	1	PASI-O
70148298015	CGE-01-KS-P-16	EPA 200.8	AMS	1	PASI-O
70148298016	CGE-01-SF-P-20	EPA 200.8	AMS	1	PASI-O
70148298017	CGE-01-KS-P-21	EPA 200.8	AMS	1	PASI-O
70148298018	CGE-01-KS-P-22	EPA 200.8	AMS	1	PASI-O
70148298019	CGE-01-SF-P-26	EPA 200.8	AMS	1	PASI-O
70148298020	CGE-01-SF-P-27	EPA 200.8	AMS	1	PASI-O
70148298021	CGE-01-SF-P-28	EPA 200.8	AMS	1	PASI-O
70148298022	CGE-01-SF-P-30	EPA 200.8	AMS	1	PASI-O
70148298023	CGE-01-WF-P-32	EPA 200.8	AMS	1	PASI-O
70148298024	CGE-01-SF-P-33	EPA 200.8	AMS	1	PASI-O
70148298025	CGE-01-WF-P-35	EPA 200.8	AMS	1	PASI-O
70148298026	CGE-01-SF-P-36	EPA 200.8	AMS	1	PASI-O
70148298027	CGE-01-SF-P-37	EPA 200.8	AMS	1	PASI-O
70148298028	CGE-01-1M-P-38	EPA 200.8	AMS	1	PASI-O
70148298029	CGE-01-1M-P-39	EPA 200.8	AMS	1	PASI-O

PASI-O = Pace Analytical Services - Ormond Beach

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-01	Lab ID: 70148298001	Collected: 09/25/20 04:54	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 14:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-DW-P-02 Lab ID: 70148298002 Collected: 09/25/20 04:56 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-BF-P-03	Lab ID: 70148298003	Collected: 09/25/20 04:56	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		10/09/20 15:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-SF-P-04 Lab ID: 70148298004 Collected: 09/25/20 04:57 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	1.9	ug/L	1.0	1		10/09/20 15:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-15	Lab ID: 70148298005	Collected: 09/25/20 05:00	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	10.5	ug/L	1.0	1		10/09/20 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-06	Lab ID: 70148298006	Collected: 09/25/20 05:01	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-SF-P-08								
Lab ID: 70148298007								
Collected: 09/25/20 05:03								
Received: 10/06/20 10:30								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	1.7	ug/L	1.0	1		10/09/20 15:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-WF-P-09 Lab ID: 70148298008 Collected: 09/25/20 05:03 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		10/09/20 15:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-10	Lab ID: 70148298009	Collected: 09/25/20 05:05	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		10/09/20 15:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-11	Lab ID: 70148298010	Collected: 09/25/20 05:05	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<1.0	ug/L	1.0	1		10/09/20 15:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-WF-P-12 Lab ID: 70148298011 Collected: 09/25/20 05:06 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		10/09/20 15:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-BF-P-13	Lab ID: 70148298012	Collected: 09/25/20 05:06	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-IM-P-14	Lab ID: 70148298013	Collected: 09/25/20 05:11	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	5.3	ug/L	1.0	1		10/09/20 15:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-KF-P-15								
Lab ID: 70148298014								
Collected: 09/25/20 05:11								
Received: 10/06/20 10:30								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	5.2	ug/L	1.0	1		10/09/20 15:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-KS-P-16	Lab ID: 70148298015	Collected: 09/25/20 05:11	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	3.2	ug/L	1.0	1		10/09/20 15:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-SF-P-20 Lab ID: 70148298016 Collected: 09/25/20 05:25 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.0	ug/L	1.0	1		10/09/20 15:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-KS-P-21	Lab ID: 70148298017	Collected: 09/25/20 05:29	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	1.9	ug/L	1.0	1		10/09/20 15:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-KS-P-22	Lab ID: 70148298018	Collected: 09/25/20 05:29	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		10/09/20 15:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-SF-P-26								
Lab ID: 70148298019								
Collected: 09/25/20 05:32								
Received: 10/06/20 10:30								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-27	Lab ID: 70148298020	Collected: 09/25/20 05:40	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	1.2	ug/L	1.0	1		10/09/20 15:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-SF-P-28								
Lab ID: 70148298021								
Collected: 09/25/20 05:37								
Received: 10/06/20 10:30								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-SF-P-30 Lab ID: 70148298022 Collected: 09/25/20 05:45 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	11.0	ug/L	1.0	1		10/09/20 15:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-WF-P-32		Lab ID: 70148298023		Collected: 09/25/20 05:42	Received: 10/06/20 10:30	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.0	ug/L	1.0	1		10/09/20 15:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-33	Lab ID: 70148298024	Collected: 09/25/20 05:49	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	6.8	ug/L	1.0	1		10/09/20 15:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-WF-P-35								
Lab ID: 70148298025								
Collected: 09/25/20 05:50								
Received: 10/06/20 10:30								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-SF-P-36	Lab ID: 70148298026	Collected: 09/25/20 05:51	Received: 10/06/20 10:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25
Pace Project No.: 70148298

Sample: CGE-01-SF-P-37	Lab ID: 70148298027	Collected: 09/25/20 05:52	Received: 10/06/20 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	<1.0	ug/L	1.0	1		10/09/20 15:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: CGE-01-1M-P-38 Lab ID: 70148298028 Collected: 09/25/20 05:25 Received: 10/06/20 10:30 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach								
Lead	<1.0	ug/L	1.0	1		10/09/20 15:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/25

Pace Project No.: 70148298

Sample: CGE-01-1M-P-39		Lab ID: 70148298029	Collected: 09/25/20 05:26	Received: 10/06/20 10:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	<1.0	ug/L	1.0	1		10/09/20 15:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: LEADS 9/25
Pace Project No.: 70148298

QC Batch:	672188	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach

Associated Lab Samples: 70148298013, 70148298014, 70148298015, 70148298016, 70148298017, 70148298018, 70148298019, 70148298020, 70148298021, 70148298022, 70148298023, 70148298024, 70148298025, 70148298026, 70148298027, 70148298028, 70148298029

METHOD BLANK: 3656728 Matrix: Water
Associated Lab Samples: 70148298013, 70148298014, 70148298015, 70148298016, 70148298017, 70148298018, 70148298019, 70148298020, 70148298021, 70148298022, 70148298023, 70148298024, 70148298025, 70148298026, 70148298027, 70148298028, 70148298029

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/09/20 15:43	

LABORATORY CONTROL SAMPLE: 3656729

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3656724 3656725

Parameter	Units	70148298013 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	5.3	50	50	56.2	56.3	102	102	70-130	0	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3656726 3656727

Parameter	Units	70148300003 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	5.1	50	50	55.5	56.5	101	103	70-130	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: LEADS 9/25

Pace Project No.: 70148298

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEADS 9/25
Pace Project No.: 70148298

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70148298001	CGE-01-SF-P-01	EPA 200.8	672171		
70148298002	CGE-01-DW-P-02	EPA 200.8	672171		
70148298003	CGE-01-BF-P-03	EPA 200.8	672171		
70148298004	CGE-01-SF-P-04	EPA 200.8	672171		
70148298005	CGE-01-SF-P-15	EPA 200.8	672171		
70148298006	CGE-01-SF-P-06	EPA 200.8	672171		
70148298007	CGE-01-SF-P-08	EPA 200.8	672171		
70148298008	CGE-01-WF-P-09	EPA 200.8	672171		
70148298009	CGE-01-SF-P-10	EPA 200.8	672171		
70148298010	CGE-01-SF-P-11	EPA 200.8	672171		
70148298011	CGE-01-WF-P-12	EPA 200.8	672171		
70148298012	CGE-01-BF-P-13	EPA 200.8	672171		
70148298013	CGE-01-IM-P-14	EPA 200.8	672188		
70148298014	CGE-01-KF-P-15	EPA 200.8	672188		
70148298015	CGE-01-KS-P-16	EPA 200.8	672188		
70148298016	CGE-01-SF-P-20	EPA 200.8	672188		
70148298017	CGE-01-KS-P-21	EPA 200.8	672188		
70148298018	CGE-01-KS-P-22	EPA 200.8	672188		
70148298019	CGE-01-SF-P-26	EPA 200.8	672188		
70148298020	CGE-01-SF-P-27	EPA 200.8	672188		
70148298021	CGE-01-SF-P-28	EPA 200.8	672188		
70148298022	CGE-01-SF-P-30	EPA 200.8	672188		
70148298023	CGE-01-WF-P-32	EPA 200.8	672188		
70148298024	CGE-01-SF-P-33	EPA 200.8	672188		
70148298025	CGE-01-WF-P-35	EPA 200.8	672188		
70148298026	CGE-01-SF-P-36	EPA 200.8	672188		
70148298027	CGE-01-SF-P-37	EPA 200.8	672188		
70148298028	CGE-01-1M-P-38	EPA 200.8	672188		
70148298029	CGE-01-1M-P-39	EPA 200.8	672188		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CLIENT INFORMATION
 Name: Questar III BOCES
 Address: 10 Empire State Blvd. Castleton, NY 12044
 Client Rep:

Date of Sampling: 9-25-20
 Samples Taken By: PS
 Samples Taken By:

SCHOOL/PROJECT INFORMATION
 BLDG NO./N: Columbia Greene Educational Center
 131 Union Turnpike Hudson, NY 12534
 CONTACT NAME & NUMBERS:

WO#: 70148298



(1) Yr. Built: (2) Yr. 1st Add: (3) Yr. 2nd Add: (4) Yr. 1st Mod: (5) Yr. 2nd Mod:

SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Information				Remediation
				Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	
1	CGE-01-SF-P-01	Rm 4A Faculty	Sink Faucet			X	0457	
2	CGE-01-DW-P-02	Corr Main Entry	Water Fountain			X	0456	
3	CGE-01-BF-P-03	Corr Main Entry	Bottle Filler			X	0456	
4	CGE-01-SF-P-04	Rm 12A	Sink Faucet			X	0457	
5	CGE-01-SF-P-15	Rm 3	Sink Faucet			X	0500	
6	CGE-01-SF-P-06	Rm 14A	Sink Faucet			X	0501	
7	CGE-01-WF-P-07	Rm 14A	Water Fountain			X		Removed
8	CGE-01-SF-P-08	Rm 16A	Sink Faucet			X	0503	
9	CGE-01-WF-P-09	Rm 16A	Water Fountain			X	0503	
10	CGE-01-SF-P-10	Rm 18A	Sink Faucet			X	0505	
11	CGE-01-SF-P-11	Rm 18A	Sink Faucet			X	0505	
12	CGE-01-WF-P-12	Corr By Rm 17	Water Fountain			X	0506	
13	CGE-01-BF-P-13	Corr By Rm 17	Bottle Filler			X	0506	
14	CGE-01-IM-P-14	Rm 28A	Ice Machine			X	0511	
15	CGE-01-KF-P-15	Rm 28A	Sink Faucet			X	0511	
16	CGE-01-KS-P-16	Rm 28A	Sink Faucet			X	0511	
17	CGE-01-KS-P-17	Rm 28A	Sink Faucet			X		no longer valid
18	CGE-01-KS-P-18	Rm 28A	Sink Faucet			X		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: [Signature] Date: 10-5-20
 Received By: [Signature] Date: 10-5-20
 INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: PACE
 Contact: [Blank]
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION
 Name: Questar III BOCES
 Address: 10 Empire State Blvd. Castleton, NY 12033
 Client Rep:

SCHOOL/PROJECT INFORMATION
 BLDG NO./N: Columbia Greene Educational Center
 BLDG ADDRESS: 131 Union Turnpike Hudson, NY 12534
 CONTACT NAME & NUMBERS:

(1) Yr. Built: (2) Yr. 1st Add: (3) Yr. 2nd Add: (4) Yr. 1st Mod: (5) Yr. 2nd Mod:

Date of Sampling: 9-25-20
 Samples Taken By: PS
 Samples Taken By:

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Outlet Information		
								Lead	Copper	Remediation
19	CGE-01-KS-P-10	Rm 28A	Sink Faucet			X		X		no longer valid.
20	CGE-01-SF-P-20	Rm 30A Side Rm	Sink Faucet			X	0525	X		
21	CGE-01-KS-P-21	Rm 30B	Sink Faucet			X	0529	X		
22	CGE-01-KS-P-22	Rm 30B	Sink Faucet			X	0529	X		
23	CGE-01-KS-P-23	Rm 30B	Sink Faucet			X		X		no longer valid
24	CGE-01-IM-P-24	Rm 30B	Ice Machine			X		X		moved 30A
25	CGE-01-SF-P-25	Rm 32A	Sink Faucet			X		X		no longer valid
26	CGE-01-SF-P-26	Rm 32A	Sink Faucet			X	0532	X		
27	CGE-01-SF-P-27	Nurse	Sink Faucet			X	0540	X		
28	CGE-01-SF-P-28	Rm 32E	Sink Faucet			X	0537	X		
29	CGE-01-SF-P-29	Rm 31D	Sink Faucet			X		X		no longer valid
30	CGE-01-SF-P-30	Rm 31	Sink Faucet			X	0545	X		no longer valid
31	CGE-01-SF-P-31	Rm 33	Sink Faucet			X		X		no longer valid
32	CGE-01-WF-P-32	Corr by Rm 33	Water Fountain			X		X		
33	CGE-01-SF-P-33	Rm 25B	Sink Faucet			X	0547	X		
34	CGE-01-SF-P-34	Rm 24A	Sink Faucet			X	0549	X		mixing valve
35	CGE-01-WF-P-35	Corr by Rm 22A	Water Fountain			X	0550	X		
36	CGE-01-SF-P-36	Rm 22A	Sink Faucet			X	0551	X		
37	CGE-01-SF-P-37	Rm 20A	Sink Faucet			X	0552	X		
38	CGE-01-IM-P-38	Rm 30A	ICE MACHINE			X	0525	X		
39	CGE-01-IM-P-39	Rm 28A	ICE MACHINE			X	0526	X		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY
 Relinquished By: [Signature]
 Received By: [Signature]
 Date: 10-5-20
 Time: 9:50
 Date: 10/17/20
 Time: 10:30
 20.0 N

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: PACE

Contact: [Blank]

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO#: 70148298

Client Name:

Project

PM: NML

Due Date: 10/20/20

CLIENT: QUESTAR

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: 9099 9900 9742

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Type of Ice: Wet Blue None

Thermometer Used: TH091

Correction Factor: -0.2

Samples on ice, cooling process has begun

Cooler Temperature (°C): 20.0

Cooler Temperature Corrected (°C): 19.8

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 10/14/20 SJ

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD):	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL WT OIL			
All containers needing preservation have been checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #			Sample # Sample 005's bottle
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Says CGE-01-SF-P-05 RM3. Logged per COC
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #			Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):			

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: