

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
REC-01-CF-P-01	9/3/2020 05:29	9/14/2020 12:49	70145008001	Lead	6.6	15	ug/L
REC-01-RS-P-02	9/3/2020 05:30	9/14/2020 13:14	70145008002	Lead	7.2	15	ug/L
REC-01-BF-P-03	9/3/2020 05:30	9/14/2020 12:54	70145008003	Lead	3.9	15	ug/L
REC-01-KF-P-04	9/3/2020 05:23	9/14/2020 12:55	70145008004	Lead	1.7	15	ug/L
REC-01-KF-P-05	9/3/2020 05:23	9/14/2020 12:56	70145008005	Lead	1.3	15	ug/L
REC-01-KF-P-06	9/3/2020 05:23	9/14/2020 12:59	70145008006	Lead	13.3	15	ug/L
REC-01-KF-P-07	9/3/2020 05:25	9/14/2020 13:00	70145008007	Lead	25.4	15	ug/L
REC-01-KF-P-08	9/3/2020 05:25	9/14/2020 13:01	70145008008	Lead	3.7	15	ug/L
REC-01-KF-P-09	9/3/2020 05:27	9/14/2020 13:02	70145008009	Lead	14.8	15	ug/L
REC-01-KF-P-10	9/3/2020 05:27	9/14/2020 13:03	70145008010	Lead	24.3	15	ug/L
REC-01-KF-P-11	9/3/2020 05:28	9/14/2020 13:03	70145008011	Lead	31.3	15	ug/L
REC-01-KF-P-12	9/3/2020 05:40	9/14/2020 13:06	70145008012	Lead	4.7	15	ug/L
REC-01-KF-P-13	9/3/2020 05:40	9/14/2020 13:07	70145008013	Lead	<1.0	15	ug/L
REC-01-WF-P-14	9/3/2020 05:44	9/14/2020 13:10	70145008014	Lead	<1.0	15	ug/L
REC-01-BF-P-15	9/3/2020 05:44	9/14/2020 13:11	70145008015	Lead	1.1	15	ug/L
REC-01-CF-P-16	9/3/2020 05:46	9/14/2020 13:12	70145008016	Lead	2.9	15	ug/L
REC-01-RS-P-17	9/3/2020 05:47	9/14/2020 13:13	70145008017	Lead	20.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

September 14, 2020

Paul Swieton
Rensselaer-Columbia-Greene Counties and
BOCES
10 Empire State Blvd.
Fl 2
Castleton On Hudson, NY 12033

RE: Project: LEADS 9/3
Pace Project No.: 70145008

Dear Paul Swieton:

Enclosed are the analytical results for sample(s) received by the laboratory on September 08, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: LEADS 9/3

Pace Project No.: 70145008

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-CF-P-01		Lab ID: 70145008001	Collected: 09/03/20 05:29	Received: 09/08/20 10:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.6	ug/L	1.0	1		09/14/20 12:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-RS-P-02	Lab ID: 70145008002	Collected: 09/03/20 05:30	Received: 09/08/20 10:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.2	ug/L	1.0	1		09/14/20 13:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: REC-01-BF-P-03								
Lab ID: 70145008003								
Collected: 09/03/20 05:30								
Received: 09/08/20 10:55								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.9	ug/L	1.0	1		09/14/20 12:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-04		Lab ID: 70145008004		Collected: 09/03/20 05:23	Received: 09/08/20 10:55	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		09/14/20 12:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-05		Lab ID: 70145008005	Collected: 09/03/20 05:23	Received: 09/08/20 10:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		09/14/20 12:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-06		Lab ID: 70145008006	Collected: 09/03/20 05:23	Received: 09/08/20 10:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.3	ug/L	1.0	1		09/14/20 12:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: REC-01-KF-P-07								
Lab ID: 70145008007								
Collected: 09/03/20 05:25 Received: 09/08/20 10:55 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	25.4	ug/L	1.0	1		09/14/20 13:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: REC-01-KF-P-08								
Lab ID: 70145008008								
Collected: 09/03/20 05:25								
Received: 09/08/20 10:55								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.7	ug/L	1.0	1		09/14/20 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-09	Lab ID: 70145008009	Collected: 09/03/20 05:27	Received: 09/08/20 10:55	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	14.8	ug/L	1.0	1		09/14/20 13:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-10		Lab ID: 70145008010	Collected: 09/03/20 05:27	Received: 09/08/20 10:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	24.3	ug/L	1.0	1		09/14/20 13:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-11	Lab ID: 70145008011	Collected: 09/03/20 05:28	Received: 09/08/20 10:55	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	31.3	ug/L	1.0	1		09/14/20 13:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-12	Lab ID: 70145008012	Collected: 09/03/20 05:40	Received: 09/08/20 10:55	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	4.7	ug/L	1.0	1		09/14/20 13:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-KF-P-13		Lab ID: 70145008013	Collected: 09/03/20 05:40	Received: 09/08/20 10:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		09/14/20 13:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-WF-P-14		Lab ID: 70145008014	Collected: 09/03/20 05:44	Received: 09/08/20 10:55	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		09/14/20 13:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: REC-01-BF-P-15								
Lab ID: 70145008015								
Collected: 09/03/20 05:44								
Received: 09/08/20 10:55								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.1	ug/L	1.0	1		09/14/20 13:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Sample: REC-01-CF-P-16	Lab ID: 70145008016	Collected: 09/03/20 05:46	Received: 09/08/20 10:55	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		09/14/20 13:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: LEADS 9/3

Pace Project No.: 70145008

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: REC-01-RS-P-17								
Lab ID: 70145008017								
Collected: 09/03/20 05:47								
Received: 09/08/20 10:55								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	20.0	ug/L	1.0	1		09/14/20 13:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: LEADS 9/3
Pace Project No.: 70145008

QC Batch:	177149	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70145008001, 70145008002, 70145008003, 70145008004, 70145008005, 70145008006, 70145008007, 70145008008, 70145008009, 70145008010, 70145008011, 70145008012, 70145008013, 70145008014, 70145008015, 70145008016, 70145008017		

METHOD BLANK:	859544	Matrix:	Water
Associated Lab Samples:	70145008001, 70145008002, 70145008003, 70145008004, 70145008005, 70145008006, 70145008007, 70145008008, 70145008009, 70145008010, 70145008011, 70145008012, 70145008013, 70145008014, 70145008015, 70145008016, 70145008017		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	09/14/20 12:47	

LABORATORY CONTROL SAMPLE:	859545					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.0	106	85-115	

MATRIX SPIKE SAMPLE:	859548						
Parameter	Units	70145008001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.6	4	11.2	114	70-130	

MATRIX SPIKE SAMPLE:	859550						
Parameter	Units	70145008011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	31.3	4	35.0	93	70-130	

SAMPLE DUPLICATE:	859547					
Parameter	Units	70145008001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	6.6	6.6	0		

SAMPLE DUPLICATE:	859549					
Parameter	Units	70145008011 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	31.3	30.6	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: LEADS 9/3

Pace Project No.: 70145008

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEADS 9/3
Pace Project No.: 70145008

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70145008001	REC-01-CF-P-01	EPA 200.8	177149		
70145008002	REC-01-RS-P-02	EPA 200.8	177149		
70145008003	REC-01-BF-P-03	EPA 200.8	177149		
70145008004	REC-01-KF-P-04	EPA 200.8	177149		
70145008005	REC-01-KF-P-05	EPA 200.8	177149		
70145008006	REC-01-KF-P-06	EPA 200.8	177149		
70145008007	REC-01-KF-P-07	EPA 200.8	177149		
70145008008	REC-01-KF-P-08	EPA 200.8	177149		
70145008009	REC-01-KF-P-09	EPA 200.8	177149		
70145008010	REC-01-KF-P-10	EPA 200.8	177149		
70145008011	REC-01-KF-P-11	EPA 200.8	177149		
70145008012	REC-01-KF-P-12	EPA 200.8	177149		
70145008013	REC-01-KF-P-13	EPA 200.8	177149		
70145008014	REC-01-WF-P-14	EPA 200.8	177149		
70145008015	REC-01-BF-P-15	EPA 200.8	177149		
70145008016	REC-01-CF-P-16	EPA 200.8	177149		
70145008017	REC-01-RS-P-17	EPA 200.8	177149		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: Questar III
 Address: 10 Empire State Blvd. Castleton NY 12033

Client Rep: _____

SCHOOL/PROJECT INFORMATION

BLDG NO./N. Rensselaer Education Center
 BLDG ADDR 35 Colleen Rd. NY 12180

CONTACT NAME & NUMBERS: Paul Swieton 518-479-6969 & 519-265-9531

(1) Yr. Built: _____ (2) Yr. 1st Add: _____ (3) Yr. 2nd Add: _____ (4) Yr. 1st Mod: _____ (5) Yr. 2nd Mod: _____

Date of Sampling: 9-3-20
 Samples Taken By: PS
 Samples Taken By: _____



SAMPLE DATA

Sample Description ID (ID must match container label)

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Information			Time of Collection (24hr)	Lead	Copper	Remediation
				Outlet Make & Model	Construct. Date	First Draw				
1	REC-01-CF-P-01	Science Classroom	Classroom Faucet			X	0529	X		
2	REC-01-RS-P-02	Nurses Office	Sink			X	0530	X		
3	REC-01-BF-P-03	Nurses Bathroom	Bathroom Faucet				0530			
4	REC-01-KF-P-04	Intro to Foods #1	Kitchen Faucet			X	0523	X		
5	REC-01-KF-P-05	Intro to Foods #2	Kitchen Faucet			X	0523	X		
6	REC-01-KF-P-06	Intro to Foods #3	Kitchen Faucet			X	0523	X		
7	REC-01-KF-P-07	Intro to Foods #4	Kitchen Faucet			X	0525	X		
8	REC-01-KF-P-08	Intro to Foods #5	Kitchen Faucet			X	0525	X		
9	REC-01-KF-P-09	Culinary #1	Kitchen Faucet			X	0527	X		
10	REC-01-KF-P-10	Culinary #2	Kitchen Faucet			X	0527	X		
11	REC-01-KF-P-11	Culinary #3	Kitchen Faucet			X	0528	X		
12	REC-01-KF-P-12	Culinary #4	Kitchen Faucet			X	0540	X		
13	REC-01-KF-P-13	Culinary #5	Kitchen Faucet			X	0547	X		
14	REC-01-WF-P-14	A Wing Corr	Water Fountain			X	0547	X		
15	REC-01-BF-P-15	A Wing Corr	Bottle Filler			X	0549	X		
16	REC-01-CF-P-16	Art Sink	Classroom Faucet			X	0546	X		
17	REC-01-RS-P-17	Faculty Room	Sink			X	0547	X		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: *[Signature]* Received By: *[Signature]* PACE
 V.S. 6/3/20
 10:55 9/4/20
 Time: 10:55 Date: 9/13/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE

Contact: _____

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO#: 70145008

Client Name: _____

 PM: NML Due Date: 09/22/20
 CLIENT: QUESTAR

 Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: 9099 9900 8974

 Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

 Temperature Blank Present: Yes No

 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

 Type of Ice: Wet Blue None

Thermometer Used: TH091 Correction Factor: +0.4

 Samples on ice, cooling process has begun

Cooler Temperature (°C): 20.0 Cooler Temperature Corrected (°C): 20.4

Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C

 USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: JT 9/14/20

 Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

 Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL WT OIL			
All containers needing preservation have been checked	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>Head 82m</u>			Sample # <u>ALL SAMPLES.</u>
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: <u>JT.</u> Lot # of added preservative: <u>1793a</u> Date/Time preservative added: <u>9/18/20 15:19</u>
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #			
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____			

Client Notification/ Resolution: _____

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____