

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GW-01-CF-P-01	1	Classroom Faucet	4/28/2021 06:17	5/12/2021 21:53	70171416001	Lead	<1.0	15	ug/L	
GW-01-BF-P-03	1	Bathroom Faucet	4/28/2021 06:17	5/12/2021 21:54	70171416002	Lead	1.1	15	ug/L	
GW-01-CF-P-04	2	Classroom Faucet	4/28/2021 06:17	5/12/2021 21:55	70171416003	Lead	<1.0	15	ug/L	
GW-01-BF-P-06	2	Bathroom Faucet	4/28/2021 06:18	5/12/2021 21:56	70171416004	Lead	1.3	15	ug/L	
GW-01-CF-P-07	4	Classroom Faucet	4/28/2021 06:19	5/12/2021 21:58	70171416005	Lead	2.4	15	ug/L	
GW-01-BF-P-09	4	Bathroom Faucet	4/28/2021 06:19	5/12/2021 22:00	70171416006	Lead	<1.0	15	ug/L	
GW-01-CF-P-10	5	Classroom Faucet	4/28/2021 06:20	5/12/2021 22:00	70171416007	Lead	2.7	15	ug/L	
GW-01-BF-P-12	5	Bathroom Faucet	4/28/2021 06:20	5/12/2021 22:01	70171416008	Lead	<1.0	15	ug/L	
GW-01-CF-P-15	6	Classroom Faucet	4/28/2021 06:21	5/12/2021 22:02	70171416009	Lead	4.0	15	ug/L	
GW-01-CF-P-17	7	Classroom Faucet	4/28/2021 06:21	5/12/2021 22:05	70171416010	Lead	5.1	15	ug/L	
GW-01-CF-P-19	9	Classroom Faucet	4/28/2021 06:22	5/12/2021 22:10	70171416011	Lead	1.7	15	ug/L	
GW-01-CF-P-21	10	Classroom Faucet	4/28/2021 06:22	5/12/2021 22:11	70171416012	Lead	<1.0	15	ug/L	
GW-01-BF-P-23	Girl's Restroom - L	Bathroom Faucet	4/28/2021 06:22	5/12/2021 22:12	70171416013	Lead	<1.0	15	ug/L	
GW-01-BF-P-24	Girl's Restroom - R	Bathroom Faucet	4/28/2021 06:22	5/12/2021 22:13	70171416014	Lead	<1.0	15	ug/L	
GW-01-BF-P-26	Boy's Restroom - L	Bathroom Faucet	4/28/2021 06:22	5/12/2021 22:14	70171416015	Lead	<1.0	15	ug/L	
GW-01-BF-P-27	Boy's Restroom - R	Bathroom Faucet	4/28/2021 06:22	5/12/2021 22:15	70171416016	Lead	<1.0	15	ug/L	
GW-01-SF-P-28	11	Sink Faucet	4/28/2021 06:25	5/12/2021 22:16	70171416017	Lead	<1.0	15	ug/L	
GW-01-CF-P-29	12	Classroom Sink Faucet	4/28/2021 06:25	5/12/2021 22:17	70171416018	Lead	<1.0	15	ug/L	
GW-01-CF-P-30	13	Classroom Sink Faucet	4/28/2021 06:25	5/12/2021 22:18	70171416019	Lead	<1.0	15	ug/L	
GW-01-NF-P-31	Nurse	Sink Faucet	4/28/2021 06:25	5/12/2021 22:19	70171416020	Lead	<1.0	15	ug/L	
GW-01-BF-P-32	Nurse Restroom	Bathroom Faucet	4/28/2021 06:25	5/12/2021 22:23	70171416021	Lead	<1.0	15	ug/L	
GW-01-BF-P-33	Main Office Restroom	Bathroom Faucet	4/28/2021 06:26	5/12/2021 22:24	70171416022	Lead	<1.0	15	ug/L	
GW-01-CF-P-34	14	Classroom Sink Faucet	4/28/2021 06:27	5/12/2021 22:25	70171416023	Lead	<1.0	15	ug/L	
GW-01-DW-P-35	Gym Corridor Bottle Filler	Bottle Filler	4/28/2021 06:27	5/12/2021 22:26	70171416024	Lead	<1.0	15	ug/L	
GW-01-DW-P-36	Gym Corridor Water Fountain	Water Fountain	4/28/2021 06:29	5/12/2021 22:27	70171416025	Lead	<1.0	15	ug/L	
GW-01-BF-P-37	Girl's Restroom by Gym - L	Bathroom Faucet	4/28/2021 06:29	5/12/2021 22:28	70171416026	Lead	<1.0	15	ug/L	
GW-01-BF-P-38	Girl's Restroom by Gym - R	Bathroom Faucet	4/28/2021 06:29	5/12/2021 22:29	70171416027	Lead	<1.0	15	ug/L	
GW-01-BF-P-39	Boy's Restroom by Gym - L	Bathroom Faucet	4/28/2021 06:30	5/12/2021 22:30	70171416028	Lead	<1.0	15	ug/L	
GW-01-BF-P-40	Boy's Restroom by Gym - R	Bathroom Faucet	4/28/2021 06:30	5/12/2021 22:33	70171416029	Lead	<1.0	15	ug/L	
GW-01-KF-P-41	Kitchen - Handwash on Corridor Wall	Sink Faucet	4/28/2021 06:31	5/12/2021 22:36	70171416030	Lead	2.9	15	ug/L	
GW-01-KF-P-42	Kitchen - Handwash by Maint Office	Sink Faucet	4/28/2021 06:31	5/12/2021 22:38	70171416031	Lead	1.3	15	ug/L	
GW-01-KF-P-43	Kitchen - Main Sink - L	Sink Faucet	4/28/2021 06:31	5/12/2021 22:39	70171416032	Lead	1.5	15	ug/L	
GW-01-KF-P-44	Kitchen - Main Sink - R	Sink Faucet	4/28/2021 06:31	5/12/2021 22:40	70171416033	Lead	25.9	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GW-01-BF-P-45	Kitchen Restroom	Bathroom Faucet	4/28/2021 06:31	5/12/2021 22:41	70171416034	Lead	<1.0	15	ug/L	
GW-01-CF-P-46	15 - L	Classroom Sink Faucet	4/28/2021 06:32	5/12/2021 22:44	70171416035	Lead	<1.0	15	ug/L	
GW-01-CF-P-47	15 - C	Classroom Sink Faucet	4/28/2021 06:32	5/12/2021 22:45	70171416036	Lead	<1.0	15	ug/L	
GW-01-CF-P-48	15 - R	Classroom Sink Faucet	4/28/2021 06:32	5/12/2021 22:46	70171416037	Lead	<1.0	15	ug/L	
GW-01-BF-P-49	16 - Restroom	Bathroom Faucet	4/28/2021 06:33	5/12/2021 22:47	70171416038	Lead	<1.0	15	ug/L	
GW-01-DW-P-50	Nurse Corridor Fountain	Water Fountain	4/28/2021 06:33	5/12/2021 22:48	70171416039	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
-------------------------	----------	--------------------	---------------------	--------------------	--------------	---------	---------	---------------------	-------	---------------------

NYSDOH Action Level for Lead of 15 ppb

May 13, 2021

Aaron Heffner
Averill Park CSD
146 Gettle Road
Lake Pleasant, NY 12108

RE: Project: GEORGE WASHINGTON SHOOL 4/28
Pace Project No.: 70171416

Dear Aaron Heffner:

Enclosed are the analytical results for sample(s) received by the laboratory on May 03, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Pace Analytical Services Long Island

Virginia Certification # 460302

Delaware Certification # NY10478

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-01	Lab ID: 70171416001	Collected: 04/28/21 06:17	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 21:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-03		Lab ID: 70171416002	Collected: 04/28/21 06:17	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		05/12/21 21:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-04	Lab ID: 70171416003	Collected: 04/28/21 06:17	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 21:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-06	Lab ID: 70171416004	Collected: 04/28/21 06:18	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	1.3	ug/L	1.0	1		05/12/21 21:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-07		Lab ID: 70171416005	Collected: 04/28/21 06:19	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		05/12/21 21:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-09		Lab ID: 70171416006	Collected: 04/28/21 06:19	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-10		Lab ID: 70171416007	Collected: 04/28/21 06:20	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		05/12/21 22:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-12		Lab ID: 70171416008	Collected: 04/28/21 06:20	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-15		Lab ID: 70171416009	Collected: 04/28/21 06:21	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		05/12/21 22:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-17	Lab ID: 70171416010	Collected: 04/28/21 06:21	Received: 05/03/21 12:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.1	ug/L	1.0	1		05/12/21 22:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GW-01-CF-P-19								
Lab ID: 70171416011								
Collected: 04/28/21 06:22								
Received: 05/03/21 12:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.7	ug/L	1.0	1		05/12/21 22:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-21	Lab ID: 70171416012	Collected: 04/28/21 06:22	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-23	Lab ID: 70171416013	Collected: 04/28/21 06:22	Received: 05/03/21 12:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/12/21 22:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-24	Lab ID: 70171416014	Collected: 04/28/21 06:22	Received: 05/03/21 12:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/12/21 22:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GW-01-BF-P-26								
Lab ID: 70171416015								
Collected: 04/28/21 06:22								
Received: 05/03/21 12:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-27		Lab ID: 70171416016	Collected: 04/28/21 06:22	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-SF-P-28	Lab ID: 70171416017	Collected: 04/28/21 06:25	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-29		Lab ID: 70171416018		Collected: 04/28/21 06:25	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-30		Lab ID: 70171416019		Collected: 04/28/21 06:25	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28
Pace Project No.: 70171416

Sample: GW-01-NF-P-31		Lab ID: 70171416020		Collected: 04/28/21 06:25	Received: 05/03/21 12:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-32		Lab ID: 70171416021	Collected: 04/28/21 06:25	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GW-01-BF-P-33								
Lab ID: 70171416022								
Collected: 04/28/21 06:26								
Received: 05/03/21 12:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-34	Lab ID: 70171416023	Collected: 04/28/21 06:27	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-DW-P-35		Lab ID: 70171416024	Collected: 04/28/21 06:27	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-DW-P-36		Lab ID: 70171416025	Collected: 04/28/21 06:29	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-37		Lab ID: 70171416026	Collected: 04/28/21 06:29	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GW-01-BF-P-38								
Lab ID: 70171416027								
Collected: 04/28/21 06:29								
Received: 05/03/21 12:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-39		Lab ID: 70171416028	Collected: 04/28/21 06:30	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/12/21 22:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-40	Lab ID: 70171416029	Collected: 04/28/21 06:30	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-KF-P-41		Lab ID: 70171416030	Collected: 04/28/21 06:31	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		05/12/21 22:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-KF-P-42		Lab ID: 70171416031	Collected: 04/28/21 06:31	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		05/12/21 22:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-KF-P-43		Lab ID: 70171416032	Collected: 04/28/21 06:31	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		05/12/21 22:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-KF-P-44		Lab ID: 70171416033	Collected: 04/28/21 06:31	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	25.9	ug/L	1.0	1		05/12/21 22:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GW-01-BF-P-45		Lab ID: 70171416034		Collected: 04/28/21 06:31	Received: 05/03/21 12:00	Matrix: Drinking Water		
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/12/21 22:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-46	Lab ID: 70171416035	Collected: 04/28/21 06:32	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GW-01-CF-P-47								
Lab ID: 70171416036								
Collected: 04/28/21 06:32								
Received: 05/03/21 12:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-CF-P-48	Lab ID: 70171416037	Collected: 04/28/21 06:32	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-BF-P-49		Lab ID: 70171416038	Collected: 04/28/21 06:33	Received: 05/03/21 12:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/12/21 22:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Sample: GW-01-DW-P-50	Lab ID: 70171416039	Collected: 04/28/21 06:33	Received: 05/03/21 12:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/12/21 22:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: GEORGE WASHINGTON SHOOL 4/28
Pace Project No.: 70171416

QC Batch: 208293 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70171416001, 70171416002, 70171416003, 70171416004, 70171416005, 70171416006, 70171416007, 70171416008, 70171416009

METHOD BLANK: 1037318 Matrix: Water
Associated Lab Samples: 70171416001, 70171416002, 70171416003, 70171416004, 70171416005, 70171416006, 70171416007, 70171416008, 70171416009

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/12/21 21:33	

LABORATORY CONTROL SAMPLE: 1037319

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE SAMPLE: 1037321

Parameter	Units	70171360021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	20.9	50	80.3	119	70-130	

MATRIX SPIKE SAMPLE: 1037323

Parameter	Units	70171360031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	31.5	50	89.7	116	70-130	

SAMPLE DUPLICATE: 1037320

Parameter	Units	70171360021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	20.9	20.8	0	

SAMPLE DUPLICATE: 1037322

Parameter	Units	70171360031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	31.5	31.6	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

QC Batch:	208295	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70171416010, 70171416011, 70171416012, 70171416013, 70171416014, 70171416015, 70171416016, 70171416017, 70171416018, 70171416019, 70171416020, 70171416021, 70171416022, 70171416023, 70171416024, 70171416025, 70171416026, 70171416027, 70171416028, 70171416029		

METHOD BLANK:	1037324	Matrix:	Water
Associated Lab Samples:	70171416010, 70171416011, 70171416012, 70171416013, 70171416014, 70171416015, 70171416016, 70171416017, 70171416018, 70171416019, 70171416020, 70171416021, 70171416022, 70171416023, 70171416024, 70171416025, 70171416026, 70171416027, 70171416028, 70171416029		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/12/21 22:03	

LABORATORY CONTROL SAMPLE:	1037325					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.5	99	85-115	

MATRIX SPIKE SAMPLE:	1037327						
Parameter	Units	70171416010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.1	50	63.9	118	70-130	

MATRIX SPIKE SAMPLE:	1037329						
Parameter	Units	70171416020 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	61.8	123	70-130	

SAMPLE DUPLICATE:	1037326					
Parameter	Units	70171416010 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	5.1	5.1	1		

SAMPLE DUPLICATE:	1037328					
Parameter	Units	70171416020 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: GEORGE WASHINGTON SHOOL 4/28
Pace Project No.: 70171416

QC Batch:	208296	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70171416030, 70171416031, 70171416032, 70171416033, 70171416034, 70171416035, 70171416036, 70171416037, 70171416038, 70171416039

METHOD BLANK: 1037330 Matrix: Water
Associated Lab Samples: 70171416030, 70171416031, 70171416032, 70171416033, 70171416034, 70171416035, 70171416036, 70171416037, 70171416038, 70171416039

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/12/21 22:34	

LABORATORY CONTROL SAMPLE: 1037331

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.1	98	85-115	

MATRIX SPIKE SAMPLE: 1037333

Parameter	Units	70171416030 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.9	50	61.2	116	70-130	

SAMPLE DUPLICATE: 1037332

Parameter	Units	70171416030 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.9	2.9	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: GEORGE WASHINGTON SHOOL 4/28

Pace Project No.: 70171416

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70171416001	GW-01-CF-P-01	EPA 200.8	208293		
70171416002	GW-01-BF-P-03	EPA 200.8	208293		
70171416003	GW-01-CF-P-04	EPA 200.8	208293		
70171416004	GW-01-BF-P-06	EPA 200.8	208293		
70171416005	GW-01-CF-P-07	EPA 200.8	208293		
70171416006	GW-01-BF-P-09	EPA 200.8	208293		
70171416007	GW-01-CF-P-10	EPA 200.8	208293		
70171416008	GW-01-BF-P-12	EPA 200.8	208293		
70171416009	GW-01-CF-P-15	EPA 200.8	208293		
70171416010	GW-01-CF-P-17	EPA 200.8	208295		
70171416011	GW-01-CF-P-19	EPA 200.8	208295		
70171416012	GW-01-CF-P-21	EPA 200.8	208295		
70171416013	GW-01-BF-P-23	EPA 200.8	208295		
70171416014	GW-01-BF-P-24	EPA 200.8	208295		
70171416015	GW-01-BF-P-26	EPA 200.8	208295		
70171416016	GW-01-BF-P-27	EPA 200.8	208295		
70171416017	GW-01-SF-P-28	EPA 200.8	208295		
70171416018	GW-01-CF-P-29	EPA 200.8	208295		
70171416019	GW-01-CF-P-30	EPA 200.8	208295		
70171416020	GW-01-NF-P-31	EPA 200.8	208295		
70171416021	GW-01-BF-P-32	EPA 200.8	208295		
70171416022	GW-01-BF-P-33	EPA 200.8	208295		
70171416023	GW-01-CF-P-34	EPA 200.8	208295		
70171416024	GW-01-DW-P-35	EPA 200.8	208295		
70171416025	GW-01-DW-P-36	EPA 200.8	208295		
70171416026	GW-01-BF-P-37	EPA 200.8	208295		
70171416027	GW-01-BF-P-38	EPA 200.8	208295		
70171416028	GW-01-BF-P-39	EPA 200.8	208295		
70171416029	GW-01-BF-P-40	EPA 200.8	208295		
70171416030	GW-01-KF-P-41	EPA 200.8	208296		
70171416031	GW-01-KF-P-42	EPA 200.8	208296		
70171416032	GW-01-KF-P-43	EPA 200.8	208296		
70171416033	GW-01-KF-P-44	EPA 200.8	208296		
70171416034	GW-01-BF-P-45	EPA 200.8	208296		
70171416035	GW-01-CF-P-46	EPA 200.8	208296		
70171416036	GW-01-CF-P-47	EPA 200.8	208296		
70171416037	GW-01-CF-P-48	EPA 200.8	208296		
70171416038	GW-01-BF-P-49	EPA 200.8	208296		
70171416039	GW-01-DW-P-50	EPA 200.8	208296		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 2

CLIENT INFORMATION

Name: Averill Park Central School District
 Address: 146 Gettle Road, Averill Park, NY 12018
 Client Rep: Aaron Heffner 518-674-7098

Date of Sampling: 4-28-21
 Samples Taken By: Bill + Annessa + Paul S.
 District Staff:
 District Staff:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: George Washington School
 BLDG ADDRESS: 344 Menemsha Ln, Troy, NY 12180
 CONTACT NAME & NUMBERS: Aaron Heffner 518-674-7098

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:



SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	GW-01-CF-P-01	1	Classroom Faucet			X	617						
2	GW-01-DW-P-02	1	Water Fountain	Out of Service - COVID		X							
3	GW-01-BF-P-03	1	Bathroom Faucet			X	617						
4	GW-01-CF-P-04	2	Classroom Faucet			X	618						
5	GW-01-DW-P-05	2	Water Fountain	Out of Service - COVID		X							
6	GW-01-BF-P-06	2	Bathroom Faucet			X	618						
7	GW-01-CF-P-07	4	Classroom Faucet			X	619						
8	GW-01-DW-P-08	4	Water Fountain	Out of Service - COVID		X							
9	GW-01-BF-P-09	4	Bathroom Faucet			X	619						
10	GW-01-CF-P-10	5	Classroom Faucet			X	620						
11	GW-01-DW-P-11	5	Water Fountain	Out of Service - COVID		X							
12	GW-01-BF-P-12	5	Bathroom Faucet			X	620						
13	GW-01-DW-P-13	6 Corridor Fountains	Water Fountain	Out of Service - COVID		X							
14	GW-01-DW-P-14	6 Corridor Fountains	Water Fountain	Out of Service - COVID		X							
15	GW-01-CF-P-15	6	Classroom Faucet			X	621						
16	GW-01-CF-P-16	6	Water Fountain	Out of Service - COVID		X							
17	GW-01-CF-P-17	7	Classroom Faucet			X	621						
18	GW-01-DW-P-18	7	Water Fountain	Out of Service - COVID		X							
19	GW-01-CF-P-19	10	Classroom Faucet			X	622						
20	GW-01-DW-P-20	9	Water Fountain	Out of Service - COVID		X							
21	GW-01-CF-P-21	9	Classroom Faucet			X	622						
22	GW-01-DW-P-22	10	Water Fountain	Out of Service - COVID		X							
23	GW-01-BF-P-23	Girl's Restroom - L	Bathroom Faucet			X	622						
24	GW-01-BF-P-24	Girl's Restroom - R	Bathroom Faucet			X	622						
25	GW-01-CF-P-25	Corridor Restroom Fountain	Water Fountain	Out of Service - COVID		X							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: [Signature] Received By: [Signature] Time: 9:00 Date: 4-30-21
 5-2-21 11:35 [Signature] 11:00 5/3/21

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services
 1570 Helderberg Ave.
 Rotterdam, NY 12306
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: Averill Park Central School District
 Address: 146 Gettle Road, Averill Park, NY 12018
 Client Rep: Aaron Heffner 518-674-7098

Date of Sampling: 4/28/21
 Samples Taken By: Paul Sweeton
 District Staff: Aaron Heffner
 District Staff: Bill Sansone

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: George Washington School
 BLDG ADDRESS: 344 Menemsha Ln, Troy, NY 12180
 CONTACT NAME & NUMBERS: Aaron Heffner 518-674-7098



(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
26	GW-01-BF-P-26	Boy's Restroom - L	Bathroom Faucet			X	6:22						
27	GW-01-BF-P-27	Boy's Restroom - R	Bathroom Faucet			X	6:22						
28	GW-01-SF-P-28	11	Sink Faucet			X	6:25						
29	GW-01-CF-P-29	12	Classroom Sink Faucet			X	6:25						
30	GW-01-CF-P-30	13	Classroom Sink Faucet			X	6:25						
31	GW-01-NF-P-31	Nurse	Sink Faucet			X	6:25						
32	GW-01-BF-P-32	Nurse Restroom	Bathroom Faucet			X	6:25						
33	GW-01-BF-P-33	Main Office Restroom	Bathroom Faucet			X	6:26						
34	GW-01-CF-P-34	14	Classroom Sink Faucet			X	6:27						
35	GW-01-DW-P-35	Gym Corridor Bottle Filler	Bottle Filler			X	6:27						
36	GW-01-DW-P-36	Gym Corridor Water Fountain	Water Fountain			X	6:29						
37	GW-01-BF-P-37	Girl's Restroom by Gym - L	Bathroom Faucet			X	6:29						
38	GW-01-BF-P-38	Girl's Restroom by Gym - R	Bathroom Faucet			X	6:29						
39	GW-01-BF-P-39	Boy's Restroom by Gym - L	Bathroom Faucet			X	6:30						
40	GW-01-BF-P-40	Boy's Restroom by Gym - R	Bathroom Faucet			X	6:30						
41	GW-01-KF-P-41	Kitchen - Handwash on Corridor Wall	Sink Faucet			X	6:31						
42	GW-01-KF-P-42	Kitchen - Handwash by Maint Office	Sink Faucet			X	6:31						
43	GW-01-KF-P-43	Kitchen - Main Sink - L	Sink Faucet			X	6:31						
44	GW-01-KF-P-44	Kitchen - Main Sink - R	Sink Faucet			X	6:31						
45	GW-01-BF-P-45	Kitchen Restroom	Bathroom Faucet			X	6:31						
46	GW-01-CF-P-46	15 - L	Classroom Sink Faucet			X	6:32						
47	GW-01-CF-P-47	15 - C	Classroom Sink Faucet			X	6:32						
48	GW-01-CF-P-48	15 - R	Classroom Sink Faucet			X	6:32						
49	GW-01-BF-P-49	16 - Restroom	Bathroom Faucet			X	6:33						
50	GW-01-DW-P-50	Nurse Corridor Fountain	Water Fountain			X	6:33						

All containers are pre-cleaned/pre-sterilized 250ml plastic bottles and will be preserved w/HNO3 @ pH by lab

CHAIN OF CUSTODY

Relinquished By: 	Received By: 	Time: 9:10	Date: 4-30-21
		12:00	5/3/21

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services
 1570 Helderberg Ave.
 Rotterdam, NY 12306
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO#: 70171416

Client Name: Averill CSD

Project: NML Due Date: 05/10/21 CLIENT: AVERILL

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: +0.0

Cooler Temperature(°C): 18.0 Cooler Temperature Corrected(°C): 18.0

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: CH 5/4/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 17 rows and 3 columns. Columns: Question, Yes/No/N/A, Comments. Includes items like Chain of Custody Present, Sampler Name & Signature on COC, pH paper Lot #, etc.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: