



NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com

CERTIFICATE OF ANALYSIS

NJ11005 / NY12046

Project Name:	Lead Schools Program	Workorder:	N041218
---------------	-----------------------------	------------	----------------

Jeremy Smith
CNA Environmental
27 Kent St
Ballston Spa, NY 12020

Project Name and Number: **Lead Schools Program**

November 08, 2016

Dear Jeremy Smith,

This report relates only to the sample(s) as received by the laboratory. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your NJAL Environmental project coordinator or laboratory manager listed at the bottom of this report at (609)-737-3477

Note: This coverage is included as part of the Analytical Report and must be retained as a permanent record thereof.


Laboratory Manager





NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com



NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/10/16 10:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041218-01	Copper	EPA 200.8	177	2.00	ug/L	1300	George Washington School-01	9/29/16 05:59	10/17/16 17:10
N041218-02	Copper	EPA 200.8	237	2.00	ug/L	1300	George Washington School-02	9/29/16 05:59	10/17/16 17:13
N041218-03	Copper	EPA 200.8	209	2.00	ug/L	1300	George Washington School-03	9/29/16 05:59	10/17/16 17:15
N041218-04	Copper	EPA 200.8	176	2.00	ug/L	1300	George Washington School-04	9/29/16 05:59	10/17/16 17:17
N041218-05	Copper	EPA 200.8	266	2.00	ug/L	1300	George Washington School-05	9/29/16 05:59	10/17/16 17:25
N041218-06	Copper	EPA 200.8	148	2.00	ug/L	1300	George Washington School-06	9/29/16 05:59	10/17/16 17:27
N041218-07	Copper	EPA 200.8	191	2.00	ug/L	1300	George Washington School-07	9/29/16 05:59	10/17/16 17:29
N041218-08	Copper	EPA 200.8	269	2.00	ug/L	1300	George Washington School-08	9/29/16 05:59	10/17/16 17:32
N041218-09	Copper	EPA 200.8	170	2.00	ug/L	1300	George Washington School-09	9/29/16 05:59	10/17/16 17:41
N041218-10	Copper	EPA 200.8	211	2.00	ug/L	1300	George Washington School-10	9/29/16 05:59	10/17/16 17:44
N041218-11	Copper	EPA 200.8	230	2.00	ug/L	1300	George Washington School-11	9/29/16 05:59	10/17/16 17:46
N041218-12	Copper	EPA 200.8	182	2.00	ug/L	1300	George Washington School-12	9/29/16 05:59	10/17/16 17:48
N041218-13	Copper	EPA 200.8	406	2.00	ug/L	1300	George Washington School-13	9/29/16 05:59	10/17/16 17:51
N041218-14	Copper	EPA 200.8	413	2.00	ug/L	1300	George Washington School-14	9/29/16 05:59	10/17/16 17:53
N041218-15	Copper	EPA 200.8	156	2.00	ug/L	1300	George Washington School-15	9/29/16 05:59	10/17/16 18:00
N041218-16	Copper	EPA 200.8	227	2.00	ug/L	1300	George Washington School-16	9/29/16 05:59	10/17/16 18:03
N041218-17	Copper	EPA 200.8	221	2.00	ug/L	1300	George Washington School-17	9/29/16 05:59	10/17/16 18:10
N041218-18	Copper	EPA 200.8	139	2.00	ug/L	1300	George Washington School-18	9/29/16 05:59	10/17/16 18:12
N041218-19	Copper	EPA 200.8	249	2.00	ug/L	1300	George Washington School-19	9/29/16 05:59	10/17/16 18:15
N041218-20	Copper	EPA 200.8	144	2.00	ug/L	1300	George Washington School-20	9/29/16 05:59	10/17/16 18:17
N041218-21	Copper	EPA 200.8	210	2.00	ug/L	1300	George Washington School-21	9/29/16 05:59	10/17/16 18:19
N041218-22	Copper	EPA 200.8	125	2.00	ug/L	1300	George Washington School-22	9/29/16 05:59	10/17/16 18:22
N041218-23	Copper	EPA 200.8	226	2.00	ug/L	1300	George Washington School-23	9/29/16 05:59	10/17/16 18:24
N041218-24	Copper	EPA 200.8	333	2.00	ug/L	1300	George Washington School-24	9/29/16 05:59	10/17/16 18:27
N041218-25	Copper	EPA 200.8	292	2.00	ug/L	1300	George Washington School-25	9/29/16 05:59	10/18/16 16:37
N041218-26	Copper	EPA 200.8	271	2.00	ug/L	1300	George Washington School-26	9/29/16 05:59	10/18/16 16:39
N041218-27	Copper	EPA 200.8	313	2.00	ug/L	1300	George Washington School-27	9/29/16 05:59	10/18/16 16:42
N041218-28	Copper	EPA 200.8	392	2.00	ug/L	1300	George Washington School-28	9/29/16 05:59	10/18/16 16:44
N041218-29	Copper	EPA 200.8	290	2.00	ug/L	1300	George Washington School-29	9/29/16 05:59	10/18/16 16:46
N041218-30	Copper	EPA 200.8	315	2.00	ug/L	1300	George Washington School-30	9/29/16 05:59	10/18/16 16:49
N041218-31	Copper	EPA 200.8	128	2.00	ug/L	1300	George Washington School-31	9/29/16 05:59	10/18/16 16:51
N041218-32	Copper	EPA 200.8	122	2.00	ug/L	1300	George Washington School-32	9/29/16 05:59	10/18/16 16:54

New Jersey Analytical Laboratories

The
cus



NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/10/16 10:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041218-33	Copper	EPA 200.8	104	2.00	ug/L	1300	George Washington School-33	9/29/16 05:59	10/18/16 16:56
N041218-34	Copper	EPA 200.8	85.4	2.00	ug/L	1300	George Washington School-34	9/29/16 05:59	10/18/16 16:58
N041218-35	Copper	EPA 200.8	166	2.00	ug/L	1300	George Washington School-35	9/29/16 05:59	10/18/16 18:48
N041218-36	Copper	EPA 200.8	108	2.00	ug/L	1300	George Washington School-36	9/29/16 05:59	10/18/16 18:50
N041218-37	Copper	EPA 200.8	114	2.00	ug/L	1300	George Washington School-37	9/29/16 05:59	10/18/16 18:52
N041218-38	Copper	EPA 200.8	127	2.00	ug/L	1300	George Washington School-38	9/29/16 05:59	10/18/16 18:55
N041218-39	Copper	EPA 200.8	125	2.00	ug/L	1300	George Washington School-39	9/29/16 05:59	10/18/16 18:57
N041218-40	Copper	EPA 200.8	118	2.00	ug/L	1300	George Washington School-40	9/29/16 05:59	10/18/16 19:00
N041218-41	Copper	EPA 200.8	279	2.00	ug/L	1300	George Washington School-41	9/29/16 05:59	10/18/16 19:02
N041218-42	Copper	EPA 200.8	96.3	2.00	ug/L	1300	George Washington School-42	9/29/16 05:59	10/18/16 19:04
N041218-43	Copper	EPA 200.8	420	2.00	ug/L	1300	George Washington School-43	9/29/16 05:59	10/18/16 19:07
N041218-44	Copper	EPA 200.8	154	2.00	ug/L	1300	George Washington School-44	9/29/16 05:59	10/18/16 19:09
N041218-45	Copper	EPA 200.8	97.7	2.00	ug/L	1300	George Washington School-45	9/29/16 05:59	10/18/16 19:21
N041218-46	Copper	EPA 200.8	142	2.00	ug/L	1300	George Washington School-46	9/29/16 05:59	10/18/16 19:24
N041218-47	Copper	EPA 200.8	207	2.00	ug/L	1300	George Washington School-47	9/29/16 05:59	10/18/16 19:26
N041218-48	Copper	EPA 200.8	234	2.00	ug/L	1300	George Washington School-48	9/29/16 05:59	10/18/16 19:29
N041218-49	Copper	EPA 200.8	162	2.00	ug/L	1300	George Washington School-49	9/29/16 05:59	10/18/16 19:31

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041218-01	Lead	EPA 200.8	0.72	0.50	ug/L	15	George Washington School-01	9/29/16 05:59	10/17/16 17:10
N041218-02	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-02	9/29/16 05:59	10/17/16 17:13
N041218-03	Lead	EPA 200.8	2.26	0.50	ug/L	15	George Washington School-03	9/29/16 05:59	10/17/16 17:15
N041218-04	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-04	9/29/16 05:59	10/17/16 17:17
N041218-05	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-05	9/29/16 05:59	10/17/16 17:25
N041218-06	Lead	EPA 200.8	1.43	0.50	ug/L	15	George Washington School-06	9/29/16 05:59	10/17/16 17:27
N041218-07	Lead	EPA 200.8	4.89	0.50	ug/L	15	George Washington School-07	9/29/16 05:59	10/17/16 17:29
N041218-08	Lead	EPA 200.8	7.97	0.50	ug/L	15	George Washington School-08	9/29/16 05:59	10/17/16 17:32
N041218-09	Lead	EPA 200.8	1.77	0.50	ug/L	15	George Washington School-09	9/29/16 05:59	10/17/16 17:41
N041218-10	Lead	EPA 200.8	2.72	0.50	ug/L	15	George Washington School-10	9/29/16 05:59	10/17/16 17:44
N041218-11	Lead	EPA 200.8	0.85	0.50	ug/L	15	George Washington School-11	9/29/16 05:59	10/17/16 17:46
N041218-12	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-12	9/29/16 05:59	10/17/16 17:48
N041218-13	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-13	9/29/16 05:59	10/17/16 17:51
N041218-14	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-14	9/29/16 05:59	10/17/16 17:53

New Jersey Analytical Laboratories

The
cus



NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/10/16 10:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041218-15	Lead	EPA 200.8	4.03	0.50	ug/L	15	George Washington School-15	9/29/16 05:59	10/17/16 18:00
N041218-16	Lead	EPA 200.8	0.90	0.50	ug/L	15	George Washington School-16	9/29/16 05:59	10/17/16 18:03
N041218-17	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-17	9/29/16 05:59	10/17/16 18:10
N041218-18	Lead	EPA 200.8	6.84	0.50	ug/L	15	George Washington School-18	9/29/16 05:59	10/17/16 18:12
N041218-19	Lead	EPA 200.8	2.22	0.50	ug/L	15	George Washington School-19	9/29/16 05:59	10/17/16 18:15
N041218-20	Lead	EPA 200.8	0.80	0.50	ug/L	15	George Washington School-20	9/29/16 05:59	10/17/16 18:17
N041218-21	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-21	9/29/16 05:59	10/17/16 18:19
N041218-22	Lead	EPA 200.8	3.08	0.50	ug/L	15	George Washington School-22	9/29/16 05:59	10/17/16 18:22
N041218-23	Lead	EPA 200.8	0.71	0.50	ug/L	15	George Washington School-23	9/29/16 05:59	10/17/16 18:24
N041218-24	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-24	9/29/16 05:59	10/17/16 18:27
N041218-25	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-25	9/29/16 05:59	10/18/16 16:37
N041218-26	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-26	9/29/16 05:59	10/18/16 16:39
N041218-27	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-27	9/29/16 05:59	10/18/16 16:42
N041218-28	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-28	9/29/16 05:59	10/18/16 16:44
N041218-29	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-29	9/29/16 05:59	10/18/16 16:46
N041218-30	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-30	9/29/16 05:59	10/18/16 16:49
N041218-31	Lead	EPA 200.8	0.72	0.50	ug/L	15	George Washington School-31	9/29/16 05:59	10/18/16 16:51
N041218-32	Lead	EPA 200.8	0.89	0.50	ug/L	15	George Washington School-32	9/29/16 05:59	10/18/16 16:54
N041218-33	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-33	9/29/16 05:59	10/18/16 16:56
N041218-34	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-34	9/29/16 05:59	10/18/16 16:58
N041218-35	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-35	9/29/16 05:59	10/18/16 18:48
N041218-36	Lead	EPA 200.8	2.58	0.50	ug/L	15	George Washington School-36	9/29/16 05:59	10/18/16 18:50
N041218-37	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-37	9/29/16 05:59	10/18/16 18:52
N041218-38	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-38	9/29/16 05:59	10/18/16 18:55
N041218-39	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-39	9/29/16 05:59	10/18/16 18:57
N041218-40	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-40	9/29/16 05:59	10/18/16 19:00
N041218-41	Lead	EPA 200.8	24.2	0.50	ug/L	15	George Washington School-41	9/29/16 05:59	10/18/16 19:02
N041218-42	Lead	EPA 200.8	4.56	0.50	ug/L	15	George Washington School-42	9/29/16 05:59	10/18/16 19:04
N041218-43	Lead	EPA 200.8	1.05	0.50	ug/L	15	George Washington School-43	9/29/16 05:59	10/18/16 19:07
N041218-44	Lead	EPA 200.8	0.71	0.50	ug/L	15	George Washington School-44	9/29/16 05:59	10/18/16 19:09
N041218-45	Lead	EPA 200.8	4.89	0.50	ug/L	15	George Washington School-45	9/29/16 05:59	10/18/16 19:21
N041218-46	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-46	9/29/16 05:59	10/18/16 19:24

New Jersey Analytical Laboratories

The
cus



NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/10/16 10:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041218-47	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-47	9/29/16 05:59	10/18/16 19:26
N041218-48	Lead	EPA 200.8	1.40	0.50	ug/L	15	George Washington School-48	9/29/16 05:59	10/18/16 19:29
N041218-49	Lead	EPA 200.8	ND	0.50	ug/L	15	George Washington School-49	9/29/16 05:59	10/18/16 19:31



NELAC NJ11005
EPA NJ01186
PADEP 68-05417
NYDOH NY12046
BWON Approved



380 Scotch Road
Ewing, NJ 08628
609-737-3477 (p)
www.njal.com

Notes and Definitions

U	Compound not detected
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

All work performed by New Jersey Analytical Laboratories LLC, is subject to our terms and conditions of services viewable at our office and our website: <http://www.njal.com/About-NJAL/Terms-and-Conditions.aspx>

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 2

41218-49

CLIENT INFORMATION

Name: Averill Park Central School District
Address: 146 Gettle Road, Averill Park, NY 12018
Client Rep: Aaron Heffner 518-674-7098

SCHOOL/PROJECT INFORMATION

BIDG NO./NAME: George Washington School
BIDG ADDRESS: 344 Menemsha Ln, Troy, NY 12180
CONTACT NAME & NUMBERS: Aaron Heffner 518-674-7098

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

Date of Sampling:	9/29/2016
Samples Taken By:	Sam Beardsley
District Staff:	Aaron Heffner
District Staff:	John Bruce

Pb & Cu

SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Outlet Information					Service Connection	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
					Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)				
1	GW-01-CF-P-01	1	Sink Faucet			X	05:54						
2	GW-01-DW-P-02	1	Water Fountain			X	05:54						
3	GW-01-BF-P-03	1	Bathroom Faucet			X	05:54						
4	GW-01-CF-P-04	2	Sink Faucet			X	05:54						
5	GW-01-DW-P-05	2	Water Fountain			X	05:54						
6	GW-01-BF-P-06	2	Bathroom Faucet			X	05:54						
7	GW-01-CF-P-07	4	Sink Faucet			X	05:55						
8	GW-01-DW-P-08	4	Water Fountain			X	05:55						
9	GW-01-BF-P-09	4	Bathroom Faucet			X	05:55						
10	GW-01-CF-P-10	5	Sink Faucet			X	05:55						
11	GW-01-DW-P-11	5	Water Fountain			X	05:55						
12	GW-01-BF-P-12	5	Bathroom Faucet			X	05:55						
13	GW-01-DW-P-13	6 Corridor Fountains	Water Fountain			X	05:59						
14	GW-01-DW-P-14	6 Corridor Fountains	Water Fountain			X	05:59						
15	GW-01-CF-P-15	6	Sink Faucet			X	06:00						
16	GW-01-CF-P-16	6	Water Fountain			X	06:00						
17	GW-01-CF-P-17	6 Restroom	Bathroom Faucet			X	06:01						
18	GW-01-CF-P-18	7	Sink Faucet			X	06:01						
19	GW-01-DW-P-19	7	Water Fountain			X	06:01						
20	GW-01-CF-P-20	9	Sink Faucet			X	06:02						
21	GW-01-DW-P-21	9	Water Fountain			X	06:02						
22	GW-01-CF-P-22	10	Sink Faucet			X	06:04						
23	GW-01-DW-P-23	10	Water Fountain			X	06:04						
24	GW-01-BF-P-24	Girl's Restroom	Bathroom Faucet			X	06:06						
25	GW-01-BF-P-25	Girl's Restroom	Bathroom Faucet			X	06:06						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:
	C. Snyder	1227	10/3/16
	BAC	1030	10/6/16

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: CNA Environmental

Contact: Dakota Snyder 518-884-0800 x402

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: Averill Park Central School District
 Address: 146 Gettle Road, Averill Park, NY 12018
 Client Rep: Aaron Heffner 518-674-7098
 SCHOOL/PROJECT INFORMATION
 BLDG NO./NAME: George Washington School
 BLDG ADDRESS: 344 Menemsha Ln, Troy, NY 12180
 CONTRACT NAME & NUMBERS: Aaron Heffner 518-674-7098

Date of Sampling: 9/29/2016
 Samples Taken By: Sam Beardsley
 District Staff: Aaron Heffner
 District Staff: John Bruce

(1) Yr. Built: (2) Yr. 1st Add: (3) Yr. 2nd Add: (4) Yr. 1st Mod: (5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)			Outlet Information										
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
26	GW-01-CF-P-26	Corridor Restroom Fountain	Water Fountain			X	06:10:07						
27	GW-01-BF-P-27	Boy's Restroom	Bathroom Faucet			X	06:10:08						
28	GW-01-BF-P-28	Boy's Restroom	Bathroom Faucet			X	06:10:09						
29	GW-01-SF-P-29	11 Outer Room	Sink Faucet			X	06:10:13						
30	GW-01-CF-P-30	12	Sink Faucet			X	06:10:13						
31	GW-01-CF-P-31	13	Sink Faucet			X	06:10:15						
32	GW-01-NF-P-32	Nurse	Sink Faucet			X	06:10:15						
33	GW-01-BF-P-33	Nurse Restroom	Bathroom Faucet			X	06:10:15						
34	GW-01-BF-P-34	Main Office Restroom	Bathroom Faucet			X	06:10:16						
35	GW-01-CF-P-35	14	Sink Faucet			X	06:10:17						
36	GW-01-DW-P-36	Gym Corridor Fountain	Water Fountain			X	06:10:19						
37	GW-01-BF-P-37	Gym Right Restrooms	Bathroom Faucet			X	06:10:19						
38	GW-01-BF-P-38	Gym Right Restrooms	Bathroom Faucet			X	06:10:19						
39	GW-01-BF-P-39	Gym Left Restrooms	Bathroom Faucet			X	06:10:21						
40	GW-01-BF-P-40	Gym Left Restrooms	Bathroom Faucet			X	06:10:21						
41	GW-01-KF-P-41	Kitchen	Sink Faucet	50 way 2.1		X	06:10:23						
42	GW-01-KF-P-42	Kitchen	Sink Faucet			X	06:10:23						
43	GW-01-KF-P-43	Kitchen	Sink Faucet			X	06:10:23						
44	GW-01-KF-P-44	Kitchen	Sink Faucet			X	06:10:23						
45	GW-01-KF-P-45	Kitchen	Sink Faucet			X	06:10:23						
46	GW-01-BF-P-46	Kitchen Restroom	Bathroom Faucet			X	06:10:24						
47	GW-01-CF-P-47	15	Sink Faucet			X	06:10:25						
48	GW-01-CF-P-48	15	Sink Faucet			X	06:10:25						
49	GW-01-BF-P-49	16 Restroom	Bathroom Faucet			X	06:10:27						
50	GW-01-DW-P-50	Nurse Corridor Fountain	Water Fountain	omit. Changed to		X	06:10:27						

No sample 12
 All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab
 CHAIN OF CUSTODY
 Relinquished By: Received By: BAC
 Time: 1030 Date: 10-6-16
 INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)
 Lab: CNA Environmental
 Contact: Dakota Snyder 518-884-0800 x402
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody